




DO NOT SCALE  
IF IN DOUBT, ASK



DESIGN DATA :

DESIGN & CONSTRUCTION CODE	I.B.R.
MAX. WORKING PRESSURE = DESIGN PRESSURE	75 Kg/cm <sup>2</sup> (g)
HYDRAULIC TEST PRESSURE (AT SITE)	112.5 Kg/cm <sup>2</sup> (g)
SUPER-HEATER STEAM OUTLET PRESSURE AT MISSY	62.2 Kg/cm <sup>2</sup> (g)
SUPER-HEATER STEAM OUTLET TEMPERATURE	483 ± 5°C

FOR HEATING SURFACE, HEATING SURFACE AREA & NOTES  
REF. DRG. NO. D11-0FB-04372



NO.	REVISED	DATE	BY	REASON
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				
11				
12				

CUSTOMER:- OSWAL CHEMICALS AND FERTILIZERS LIMITED, ORISSA.

THIS SYMBOL IN THE BLOCK INDICATES THAT THIS BLOCK IS PICKED FROM BLOCK LIBRARY.

OR REVISION IN CAD DRAWING SHALL BE RELEASED ONLY AFTER ENSURING THAT IT IS INCORPORATED IN THE RELEVANT CAD FILE. REVISION IS INVALID IF CAD CHG SIGN IN REV. IS ABSENT.

Thermax Babcock & Wilcox Limited PUNE 411 034

BOILER NO. -WA0171C0

REF. NO.	I.B.R.
SCALE	DRAWN 22/8/2007
1:50	CHECKED
	APPROVED
DRG. NO.	REV. NO.
D11-1FB-15227	0

REV. NO.	REVISION	MADE BY	CAD. CHK. DATE	APPR BY	DATE

THIS IS A CAD DRAWING. DO NOT TAKE REPRODUCTIONS