

NOISE LEVELS IN HIGH CAPACITY AMMONIA PLANTS

Proper installation of-silencers makes a big
difference; industry standards urged

R. Caputo
E. Denmark
I. Heitner
H. C. Mayo

M. W. Kellogg Co., Inc.
New York, N. Y.

Noise has been defined as unwanted sound. Its undesirable effects can be temporary or permanent hearing loss, inability of personnel to communicate effectively, and reduction in efficiency.

A brief discussion of acoustical terminology is presented below to aid in understanding the tabulated data. Sound power is defined as energy per unit time and is measured in watts. Sound intensity is measured in watts per square meter. Since sound power can vary from 10^{-9} watts for a very soft whisper to 10^7 for a jet, a total variation of 10^{16} watts, it is normal practice to express sound power as a log function. An additional advantage of employing a log function is that the response of the human ear seems to be in direct proportion to the log of the sound intensity.

If W is the sound power of the noise source in watts and W_0 is a reference sound power (frequently taken as 10^{-12} watts) then the sound power in decibels is defined as $10 \log_{10} \frac{W}{W_0}$. Similarly, sound intensity level (I.L.) is defined in decibels using a reference intensity of 10^{-12} watts per square meter. Thus:

$$I.L. = 10 \log_{10} \frac{I}{I_0} \text{ decibels.}$$

It is difficult to measure sound power or intensity but comparatively easy to measure the variation in atmospheric pressure produced by noise, using microphones which convert the sound pressure into a voltage. It can be shown that $P^2 = \pi CI$ where:

P = root mean square sound pressure

π = the density of air

C = the velocity of sound in air, and,

I = the sound intensity (watts per square meter.).

Thus, in the definition of sound intensity instead of taking the ratio of I/L , we take the ratio of P^2/P_0^2 to obtain a definition of sound pressure level (SPD equal to $10 \log_{10} \frac{P^2}{P_0^2}$ or $SPL = 20 \log_{10} P/P_0$. P_0 , the reference pressure, is taken as 0.0002 dynes per cm^2 and thus the units of SPL are decibels referred to 0.0002 dynes per square centimeter.

Overall SPL values

To obtain a general idea of the magnitude of the readings presented in this article, general overall SPL values are presented in Table 1.

All of the noise levels presented in this article are sound pressure levels in decibels (referred to 0.0002 dynes per cm^2), correspondingly, noise levels presented in the various legal, insurance, and company specifications are usually in the same units. The instrument used for measurements in the 1,000 ton plants was a General Radio Co.—Model 1558A octave band noise analyzer. For 600 ton plant measurements, a Herman Hosmer Scott sound level meter Type 410B and sound analyzer type 420A were used.

The human ear is sensitive to frequencies between 20 and 10,000 cycles per second but the physical and psychological response to

different frequencies vary, the higher audible frequencies being the more damaging. Thus a single overall SPL reading is not a complete description of the noise since what is needed is the noise intensity as a function of frequency. It is customary to divide the frequency spectrum into bands (one typical division being 20 to 75, 75-150, 150-300, etc. up to 4800 to 10,000 cycles per second) and then to make measurements in each band. Where the upper frequency is twice the lower frequency the band is known as an octave. The data presented herein consists of frequency band readings and one overall reading.

Table 1. General overall SPL values.

Source	SPL (re 0.0002 dynes/cm ²)
Automobile horn at 3 ft.	115 (2)
Inside DC-6 Airliner	105 (2)
Air Compressor at Street construction site	102 (1)
N. Y. City Subway Train (Interior)	100 (1)
Inside auto at 50 mile/hr.	94 (1)
Inside bus at starting	92 (1)
Normal N. Y. City traffic	88 (1)

(1) M. W. Kellogg Company readings. (2): Published data

Table 2. Limiting noise levels established by California.

Frequency Band cycles/sec.	Octave Band SPL (decibels re 0.0002 dynes/cm ²) Exposure Time (per normal work day)			
	5 or more hrs.	2½ hrs.	1½ hrs.	1 hr.
	20-75	110	113	116
75-150	102	105	108	108
150-300	97	100	103	103
300-600	95	98	101	101
600-1200	95	98	101	101
1200-2400	95	98	101	101
2400-4800	95	98	101	101
4800-10,000	95	98	101	101

Specifications are required

In designing any plant for acceptable noise levels, specifications are required. Various government agencies, insurance companies, manufacturing companies and scholarly experts have prepared such specifications but no universally agreed upon standard exists in the chemical industry.

In Table 2 is an extract from Group 6.1 Noise Control Safety Orders, State of California, Article 55 Standards for Noise Control presenting limiting noise levels in various frequency bands for different exposure times.

If the limits are exceeded for the specified durations, the use of ear protectors is indicated.

It is possible to sum the SPL values in the frequency bands to give an overall SPL value. The curve in Figure 1 is useful in summing noise levels. Using the curve we note that the addition of two equal intensity sources increases the overall level by 3 decibels and the addition of two sources 10 decibels apart produces a negligible increase (0.44 db) in the overall level.

A typical example of this addition is the sum of the frequency bands of the California Noise Control Safety Levels presented in Figure 2.

The overall SPL is 111.3 or approximately 111 decibels.

In examining the California Noise Control Safety Levels three important features become apparent.

First: the greater permissible noise level in the lower frequencies.

Second: the introduction of an important variable from the safety point of view - the time of exposure.

Third: the purpose of the Orders, the prevention of hearing damage.




Figure 1. Curve above is useful in summing noise levels.




Figure 2. A typical example of addition of levels is the sum of the frequency bands noted above.

What the data shows

Data has been classified according to size of plant (600 or 1,000 con per day) and by type of operation (normal or start-up) Figures 3-8. Plot plans showing the points of measurement are included. In determining whether the noise levels are reasonable, comparison should be made with a Standard. We suggest that for the present, comparison be made with the Noise Control Safety Levels, State of California. It should be emphasized again that these levels are suggested limitations with avoidance of hearing damage as the criterion.

Comparison with the State of California levels shows the following:

600 Ton Plant-Normal Operation:

All points, except reformer furnace burner room meet the extended period safety levels. However, this room has low operator attendance requirements (less than 1 1/4 hours a day).

1,000 Ton Plant-Normal Operation:

Of the 36 readings taken, seven do not meet the State of California Safety Levels. Four of these points are in the burner area and the remaining three are in the compressor area. The burner area is an area of low operator attendance. It should be noted that the hogging jet was in operation in the compressor area during the period of data collection and therefore values obtained in the immediate vicinity of the jet may be higher than normal.

600 Ton Plant Start-Up (No Silencers):

An examination of the data indicates that three fourths of the ratings exceed the California Safety Levels.

These values will exist during every startup. The first startup with its many catalyst preparation steps has taken from one to three months: duration dependent on the extent of commissioning problems. However, subsequent startups are of short duration with atmospheric gas venting restricted to less than one day's duration.

1,000 Ton Plant - Startup (With Silencers):

Considering operator attendance requirements, all points except location 8, taken at grade below the air compressor vent, meet the California Safety Levels. Dependent on individual requirements, additional noise attenuation can be provided by means of a larger silencer and acoustical treatment. It was not possible to secure noise level readings while venting upstream of the high temperature shift converter. These values, however, should be somewhat higher than the reported values taken while venting upstream of the methanator.

Some observations have been made

An analysis of the data coupled with a knowledge of the installation and our operating experience, yields the following observations:

1. The most intense noise sources are the startup vents. Silencers do reduce these levels. This observation has been substantiated by resident personnel at 600 ton plants who were present both before and after installation of silencers on atmospheric vent piping. They reported a noticeable noise reduction but, unfortunately, numerical data to confirm this observation is unavailable.

2. Observations of the 1,000 ton plant at startup give indications that less than the expected noise attenuation was achieved while venting to atmosphere through the silencers. This is currently being investigated, and further data collection and evaluation is contemplated in the near future. One possible explanation is that other noise sources previously masked by the unsilenced vents are now the major noise producers. With this in mind, pressure reducing stations and pipe lines discharging to the atmospheric vent stacks are being reviewed. If pipe lines or pressure reducing stations are now dominant noise sources then acoustical treatment such as insulation and jacketing would be required to further attenuate noise levels.

3. If noise attenuation lower than the reported data is desired at specific equipment locations, then a variety of treatment techniques can be employed. These include not only silencers and acoustical insulation but also barriers, furnace air intake mufflers, energy absorption devices, and other plant design techniques. For confined areas of infrequent operator attendance, the use of ear protectors by operating personnel is an economical alternative.

4. It is possible for a plant to meet the requirements of the California Noise Control Safety Orders and still exceed the levels that are deemed acceptable by the plant or the local community. In the absence of plant or community specifications, actual noise

600 TPSD AMMONIA PLANT NOISE LEVELS -

NORMAL OPERATION

LOCATION OF NOISE MEASUREMENT

RECORDED SOUND PRESSURE LEVELS (db re 0.0002 DYNES/CM²)
FOR INDICATED FREQUENCY BANDS (CPS)

CALIFORNIA NOISE CONTROL SAFETY LEVELS

- 1- IN CONTROL ROOM
- 2- OUTSIDE CONTROL ROOM - SOUTH SIDE
- 3- ON AIR COMPRESSOR PLATFORM
- 4- ON REFRIGERANT COMPRESSOR PLATFORM
- 5- ON SYN GAS COMPRESSOR PLATFORM
- 6- SOUTH-WEST CORNER OF BATTERY LIMITS
- 7- NORTH-WEST CORNER OF BATTERY LIMITS
- 8- NORTH-EAST CORNER OF BATTERY LIMITS
- 9- SOUTH-EAST CORNER OF BATTERY LIMITS
- 10- BURNER END OF AUXILIARY BOILER - AT GRADE
- 11- NORTH SIDE OF METHANATOR AT GRADE
- 12- SOUTH SIDE OF METHANATOR AT GRADE
- 13- SOUTH SIDE OF CO₂ STRIPPER
- 14- BETWEEN TWO SOLVENT CIRCULATION PUMPS
- 15- WEST END OF PLANT; UNDER PIPE RACK.
- 16- IN WATER TREATING BLDG.
- 17- IN PRIMARY REFORMER BURNER SHACK
- 18- BETWEEN PRIMARY & SECONDARY REFORMERS
- 19- UNDER PIPE RACK - NEAR REFRIG FLASH DRUMS
- 20- UNDER PIPE RACK - EASTERN PART OF PLOT

OVERALL	20-75	75-150	150-300	300-600	600-1200	1200-2400	2400-4800	4800-9600	9600-20Kc
	110	102	97	95	95	95	95	95 (4800-10000)	
70	67	53	52	38	27	25	29	24	—
95	84	81	87	77	77	68	67	63	57
94	80	82	82	80	82	84	85	77	73
94	81	81	84	80	81	82	83	75	69
99	81	85	ft*	63	88	86	92	84	81
85	80	76	76	72	71	73	70	66	61
83	75	74	75	69	72	71	63	42	36
90	83	74	77	76	74	72	69	60	49
80	74	73	72	68	66	64	62	52	43
101	93	92	94	89	84	82	83	79	71
95	89	85	84	80	78	76	75	70	60
94	78	86	84	79	79	78	73	74	69
99	82	86	85	84	63	87	85	88	85
96	79	80	84	88	82	81	82	76	72
85	77	74	76	76	63	63	73	65	59
84	76	75	75	74	73	73	76	66	60
114	101	104	99	101	100	103	106	106	102
95	86	86	82	79	76	77	77	74	70
94	80	85	83	79	79	77	86	77	72
93	M	82	83	79	80	81	fc0	76	72

600 TPSD AMMONIA PLANT NOISE LEVELS - (VENT SILENCERS NOT PROVIDED)

START-UP OPERATION

THE FOLLOWING MEASUREMENTS WERE RECORDED WHILE VENTING UPSTREAM OF THE SHIFT CONVERTER AT THE TOP OF THE STEAM DRUM STRUCTURE (70-75% OF NORMAL FLOW)

- 11- IN WATER TREATING AREA
- 22- 35' FROM BURNERS ON AUXILIARY BOILER
- 23- ON BURNER PLATFORM OF AUXILIARY BOILER
- 24- 20' SOUTH OF DOOR TO LABORATORY
- 25- ON STEAM DRUM PLATFORM - 8' FROM VENT
- 26- IN PRIMARY REFORMER BURNER SHACK
- 27- ON PLATFORM OF SYN. GAS COMPRESSOR
- 28- ON PLATFORM OF REFRIGERANT COMPRESSOR

OVERALL	19.75-37.5	37.5-75	75-150	150-300	300-600	600-1200	1200-2400	2400-4800	4800-9600	9600-19.2Kc
100	82	64	89	92	92	88	91	94	87	69
98	90	93	90	91	88	83	86	87	82	67
116	99	109	103	112	108	104	101	98	97	85
101	80	86	93	94	96	93	95	97	93	76
120	HO	108	105	112	111	108	111	117	113	97
108	95	98	97	100	96	98	104	102	90	90
107	90	95	86	91	33	96	101	103	100	86
107	90	91	86	89	90	95	99	101	97	93

Figure 3. Noise levels in a 600 ton ammonia plant; normal operation.

600 TPSD AMMONIA PLANT




Figure 4. Plot plan of 600 ton plant showing measurement points.

1000 TPSD AMMONIA PLANT NOISE LEVELS - (W/ST SILENCERS PROVIDED)
START-UP OPERATION

THE FOLLOWING READINGS WERE RECORDED DURING START-UP, WHILE VENTING UPSTREAM OF METHANATOR AND FROM AIR COMPRESSOR EXHAUST. (FLOWS APPROXIMATELY 62% OF NORMAL)

LOCATION OF READING	RECORDED SOUND PRESSURE LEVELS (db in 0.0002 dynes/cm ²) OR INDICATED FREQUENCY BANDS (CPS)										
	OVERALL	125-375	375-750	750-1500	1500-3000	3000-6000	6000-12000	12000-24000	24000-48000	48000-96000	96000-192000
1- EAST BATTERY LIMIT	W	83	82	79	78	75	73	V	75	76	66
2- IN PRIMARY REFORMER BURNER SHACK	104	86	81	96	95	96	92	91	94	97	91
3- BETWEEN PRIMARY & SECONDARY REFORMER AT GRADE	101	86	81	90	90	86	88	93	93	95	88
4- NORTH END OF STEAM DRUM PLATFORM	100	86	87	88	88	85	88	91	94	90	81
5- SOUTH END OF STEAM DRUM PLATFORM	104	86	88	89	97	99	94	94	96	90	85
6- ON BURNER PLATFORM OF AUXILIARY BOILER	108	92	104	96	100	102	95	93	93	92	91
7- SOUTH OF AUXILIARY BOILER - ABOUT 20' AWAY	101	89	94	91	94	89	64	93	94	89	81
8- AT GRADE; BELOW AIR COMPRESSOR VENT	107	84	88	93	94	93	97	103	104	99	90
9- NORTH OF SECONDARY REFORMER - ABOUT 20' AWAY	101	60	87	86	84	85	91	94	94	97	92
10- EAST OF DESULFURIZER; ON ROAD	101	64	84	82	92	85	87	92	W	96	90
11- NORTH BATTERY LIMIT	90	79	-1	74	79	76	77	81	65	78	<7
12- IN CONTROL ROOM	81	77	73	74	63	61	58	62	64	59	49
13- NORTH OF METHANATOR	45	82	85	84	U	71	83	87	89	88	<1
14- UNDER PIPE RACK - NORTH OF SYN. GAS COMPRESSOR	100	84	86	84	M	-7	88	94	94	93	90
15- SOUTH BATTERY LIMIT	99	84	88	87	91	86	67	92	93	90	81
16- NORTH SIDE W/ CO ₂ STRIPPER - ABOUT 20' AWAY	92	81	84	83	82	81	80	64	84	81	72
17- IN LOW PRESSURE EXCHANGER AREA	91	80	83	82	82	79	80	88	81	76	69
18- NORTH OF CO ₂ ABSORBER - ABOUT 5' AWAY	57	60	80	80	80	76	74	76	75	72	<t
19- WEST BATTERY LIMIT	87	82	83	80	7*	71	72	78	77	72	64

Figure 5. Noise levels in a 1,000 ton ammonia plant; at start-up.

levels can vary over a wide range from values that allow easy plant communication and community comfort to shattering values that are uncomfortable, fatiguing and potentially harmful.

The effect on Communications

With regard to plant communication, the following observations are representative of opinions by resident personnel on the earlier units.

a). On the first 600 ton plant, communication at startup was

extremely difficult.

b). After the addition of silencers to this plant, communication at startup as well as normal operation did not present any problems except for some difficulty in the compressor and furnace areas.

c). On the silenced 1,000 ton plant, communication during startup and normal operation is acceptable except for some difficulty in the compressor and furnace areas, and adjacent pipe rack.

1000 TPSD AMMONIA PLANT NOISE LEVELS

NORMAL OPERATION

RECORDED SOUND PRESSURE LEVELS (db m 0.0002 DYNES/CM²)
FOR INDICATED FREQUENCY BANDS (CPS)

LOCATION OF NOISE MEASUREMENT

CALIFORNIA NOISE CONTROL SAFETY LEVELS

- 1- IN PRIMARY REFORMER BURNER SHACK
- 1- SOUTH-WEST CORNER OF STEAM DRUM PLATFORM
- 3- NORTH-WEST CORNER OF STEAM DRUM PLATFORM
- 4- TOP EXTERNAL PLATFORM OF PRIMARY REFORMER - NW CORNER
- 5- SAME PLATFORM M ④ - EAST SIDE OF FT. TRON. M6*
- 6- BOTTOM EXTERNAL PLATFORM OF PRIMARY REFORMER - 3' FROM TV N MEL BURNER - (NW SIDE)
- 7- SOUTH SIDE OF WATER TREATING AREA.
- 1- NORTH BATTERY LIMIT
- 9- 10' SOUTH OF CONTROL HOUSE MAIN DOOR
- 10- IN CONTROL ROOM
- 11- 15' NORTH OF SECONDARY REFORMER
- 12- ON ROAD EAST OF DESULFURIZERS
- 13- AT G(W; SOUTH-EAST SIDE OF SHIFT CONVERTER
- H- UNDER RACK, 10' WEST OF PRIMARY REFORMER FURNACE
- 15- ON LOWER BURNER PLATFORM OF AUXILIARY BOILER
- 16- 15' SOUTH OF ⑮ AT GRADE
- 17- WEST OF AUXILIARY BOILER
- 18- NORTH OF AIR COMPRESSOR UNDER RACK
- 19- 5' SOUTH OF METHANATOR
- 20- 13' NORTH OF METHANATOR
- 21- UNDER RACK, NORTH OF SYN. GAS COMPRESSOR
- 21- 5' SOUTH OF CO₂ STRIPPER
- 22- 15' NORTH OF CO₂ STRIPPER
- 24- 5' FROM LEAN SOLVENT CIRCULATION PUMP
- M- CENTER OF LOW PRESSURE EXCHANGER AREA
- 26- 5' NORTH OF CO₂ ABSORBER
- 27- 10' SOUTH OF CO₂ ABSORBER
- 28- WEST END OF REFRIGERANT FLASH DRUMS - ON PLATFORM
- 29- 10' SOUTH-WEST OF AMMONIA CONVERTER
- 30- SOUTH BATTERY LIMIT
- 31- CENTER HIGH PRESSURE EXCHANGER AREA
- 32- 4' EAST OF AMMONIA CONVERTER-TKL
- 33- UNDER RACK, CENTER OF PLOT
- 34- ON SYN. GAS COMPRESSOR PLATFORM
- 35- ON REFRIGERANT COMPRESSOR PLATFORM
- 36- ON AIR COMPRESSOR PLATFORM

OVERALL	18.75-37.5	37.5-75	75-150	150-300	300-600	100-1000	1000-2000	2000-4000	4000-9000	9000-19200	
	NO(20-75)	OV	f7	75	95	95	95	95	95 (4800-10000)		
113	88	92	97	100	100	100	100	M	101	86	
1- SOUTH-WEST CORNER OF STEAM DRUM PLATFORM	95	78	82	84	87	84	M	89	92	80	69
3- NORTH-WEST CORNER OF STEAM DRUM PLATFORM	92	76	83	83	85	80	84	85	es	75	66
4- TOP EXTERNAL PLATFORM OF PRIMARY REFORMER - NW CORNER	98	79	7	91	90	90	84	89	91	86	71
5- SAME PLATFORM M ④ - EAST SIDE OF FT. TRON. M6*	94	79	85	84	67	86	77	74	80	80	68
6- BOTTOM EXTERNAL PLATFORM OF PRIMARY REFORMER - 3' FROM TV N MEL BURNER - (NW SIDE)	112	81	92	97	93	73	97	99	103	104	92
7- SOUTH SIDE OF WATER TREATING AREA.	99	81	<7	89	81	89	87	92	94	91	78
1- NORTH BATTERY LIMIT	92	82	86	86	ftE	ftO	80	82	83	75	67
9- 10' SOUTH OF CONTROL HOUSE MAIN DOOR	76	82	61	88	89	87	7	87	87	74	70
10- IN CONTROL ROOM	81	74	74	76	74	71	73	72	41	67	67
11- 15' NORTH OF SECONDARY REFORMER	99	85	<C>	89	90	88	86	81	94	87	72
12- ON ROAD EAST OF DESULFURIZERS	96	83	88	89	89	87	67	88	<9	84	71
13- AT G(W; SOUTH-EAST SIDE OF SHIFT CONVERTER	95	86	91	sd	89	M»	86	89	96	82	70
H- UNDER RACK, 10' WEST OF PRIMARY REFORMER FURNACE	106	14	92	91	91	10	<<4	99	93	86	79
15- ON LOWER BURNER PLATFORM OF AUXILIARY BOILER	110	92	106	99	100	101	102	97	97	89	85
16- 15' SOUTH OF ⑮ AT GRADE	101	M	99	91	92	97	93	92	91	89	91
17- WEST OF AUXILIARY BOILER	94	88	90	86	87	84	83	off	88	er	72
18- NORTH OF AIR COMPRESSOR UNDER RACK	99	80	67	89	91	ft7	88	96	14	86	77
19- 5' SOUTH OF METHANATOR	94	81	87	87	91	87	66	89	87	80	71
20- 13' NORTH OF METHANATOR	M	80	85	86	91	89	86	91	86	78	77
21- UNDER RACK, NORTH OF SYN. GAS COMPRESSOR	100	83	85	86	90	86	89	92	96	90	79
21- 5' SOUTH OF CO ₂ STRIPPER	95	BS	ES	88	88	85	86	90	91	04	74
22- 15' NORTH OF CO ₂ STRIPPER	93	78	83	83	84	78	80	4	84	76	70
24- 5' FROM LEAN SOLVENT CIRCULATION PUMP	95	CO	61	85	88	84	86	89	91	83	82
M- CENTER OF LOW PRESSURE EXCHANGER AREA	92	71	77	81	86	82	<O	80	92	71	89
26- 5' NORTH OF CO ₂ ABSORBER	89	77	71	63	<1	76	79	76	76	75	69
27- 10' SOUTH OF CO ₂ ABSORBER	93	77	79	81	67	80	e»	84	84	80	69
28- WEST END OF REFRIGERANT FLASH DRUMS - ON PLATFORM	90	74	76	81	63	84	76	63	00	78	79
29- 10' SOUTH-WEST OF AMMONIA CONVERTER	87	74	77	76	75	71	71	72	74	<9	SS
30- SOUTH BATTERY LIMIT	95	87	88	86	67	87	67	88	89	82	73
31- CENTER HIGH PRESSURE EXCHANGER AREA	91	82	81	81	84	77	71	84	83	76	66
32- 4' EAST OF AMMONIA CONVERTER-TKL	89	78	77	71	82	17	77	80	60	71	47
33- UNDER RACK, CENTER OF PLOT	99	79	60	85	81	87	89	11	95	89	77
34- ON SYN. GAS COMPRESSOR PLATFORM	96	71	78	63	87	fcS	87	90	92	84	77
35- ON REFRIGERANT COMPRESSOR PLATFORM	104	70	71	85	10	89	92	98	92	U	78
36- ON AIR COMPRESSOR PLATFORM	104	70	71	82	91	89	92	92	98	88	74

Figure 7. Noise levels in a 1,000 ton ammonia plant; normal operation.

It is of interest to note that comparison of the data presented herein to speech interference levels presented in the literature would probably not be consistent with the above observations. In a recent article titled "Relieving Acoustic Fatigue" by G. C. Tolhurst (Machine Design - August, 1966), however, the following is noted - "A signal to noise ratio should be at least plus 12 db although it is possible to maintain good intelligibility of simple, connected discourse at a minus 8 db if the channel is wide enough". This point certainly confirms our observations.

Client noise requirements vary and in some cases are non-existent or unspecified. Similarly, communities bordering on

industrial plants have varying noise ordinances or none at all. Therefore, with so subjective a topic, unilateral establishment of "proper" noise levels by competitive contractors is extremely difficult. Thus, in the present age of high-capacity plants, with 1,500 ton per day plants in the offing, we suggest that definite noise standards be established for the chemical industry. Such standards could be graded to reflect the varying requirements that industrial plants and local communities may impose. However, a more suitable approach would be to adopt a minimum Standard, thereby allowing plants and communities with more stringent requirements to impose individual solutions tailored to satisfy the local environment.




Figure 6. Plot plan of 1,000 ton plant showing measurement points (Start-up).




Figure 8. Plot plan of 1,000 ton ammonia plant showing measurement points (normal).